

Effective D

In addition, if "hot work" is involved the Department of Occupational and Environmental Safety (D.O.E.S.) shall also be notified . Hot work operations include but are not limited to cutting, welding, Themit welding, brazing, soldering, grinding, thermal spraying, thawing pipe, installation of torch-applied roof systems (see CWRU Safety Procedure Manual Hot Work Program for additional information).

Planned Impairments. The impairment coordinator shall be notified by contractors/ project managers of a planned impairment no less than 48 hours in advance so a determination can be made if a fire watch is

During normal business hours on weekdays, notifications shall include:

1. Director of Residence Life and;
2. Director of Housing

If unable to reach the director, Police Dispatch will attempt to contact the appropriate associate director.

After normal business hours, on weekends, or during holidays, the Police Dispatch Center will notify the appropriate on-call person. Additional notifications to on-call professional staff and resident assistants within the affected areas will be made by those listed above.

Resident Assistants shall receive additional training on fire safety and procedures to follow when a fire alarm system is out of service. RA's will explain to all occupants during an impairment that if smoke,

The CWRU Associate Director for Emergency Management, Police and Security Services

The CWRU Protective Systems Manager (emergency impairments only)

The Fire Department having jurisdiction shall be notified of any fire watch.

Fire Watch Designee. In most instances, any qualified, competent adult may be assigned to fire watch duty (referred to as the "Fire Watch Designee.") The Fire Watch Designee shall be:

Physically capable of conducting surveillance of a building or portion thereof utilizing means

Reason fire watch was ended, and by whom

Any action taken as a result of the fire watch

Date and time of notification to Fire Department Prevention Office re: fire watch

Fire watches conducted by Police and Security Services shall be recorded by dispatch in the A.R.M.S. system.

Additionally, Fire Watch Patrol Logs shall be available for review by the fire department authority having jurisdiction.

Ending Fire Watch. A fire watch may be ended when a system is in place that meets or exceeds notification standards of the required fire protection system. The same individuals listed above who can approve a fire watch have the authority to end a fire watch. The fire department having jurisdiction shall be notified at the start and end of each fire watch.

The same processes used to notify occupants of the impairment/ fire watch will be utilized to notify them (at)-3(h)2(e)-1(h)2(all b93i2(av)(t)11)Jded whFiu8(ng)-8(F)-1(i)3(r)- Watch.ete fiFhiThrC w 26.131.9ā(n)2(-0T